

2025 ANNUAL DRINKING WATER QUALITY REPORT

Country Side Mobile Home Park PWSID # 6200028

Este informe contiene información muy importante sobre su agua de beber. Tradúzcalo ó hable con alguien que lo entienda bien. (This report contains very important information about your drinking water. Translate it, or speak with someone who understands it.)

WATER SYSTEM INFORMATION:

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact Toby Kopta at 200 West Adams St. Cochranton, PA, 16314 Telephone # (814) 720-8808. We want you to be informed about your water supply.

SOURCE OF WATER: Our water source is 2 wells located at Country Side MHP.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

MONITORING YOUR WATER

Country Side Mobile Home Park routinely monitors for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2025. The State allows us to monitor some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

DEFINITIONS AND ABBREVIATIONS:

Action Level (AL) - The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Minimum Residual Disinfectant Level - The minimum level of residual disinfectant required at the entry point to the distribution system

ppt (ng/l) = parts per trillion, or nanograms per liter

pCi/L = picocuries per liter (a measure of radioactivity)

ppm = parts per million, or milligrams per liter (mg/L)

ppb = parts per billion, or micrograms per liter (µg/L)

DETECTED SAMPLE RESULTS

Chemical Contaminant	MCL	MCLG	Highest Level Detected	Range of Detection	Units	Sample Date	Violation Y/N	Sources of Contamination
Chlorine (Distribution)	MRDL =4	MRDLG =4	0.90 (March 2025)	0.73 – 0.90	(ppm)	2025	N	Water additive used to control microbes
Fluoride	2*	2	0.278	N/A	(ppm)	3/18/24	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Barium	2	2	0.086	N/A	(ppm)	3/18/24	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Haloacetic Acids (HAA5)	60	N/A	1.64	N/A	(ppb)	8/20/25	N	By-product of drinking water disinfection
Total Trihalomethanes (TTHM)	80	N/A	5.01	N/A	(ppb)	8/20/25	N	By-product of drinking water chlorination

*EPA's MCL for fluoride is 4 ppm. However, Pennsylvania has set a lower MCL to better protect human health.

Entry Point Disinfectant Residual							
Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Units	Lowest Sample Date	Violation Y/N	Sources of Contamination
Chlorine (2025)	0.60	0.60	0.60 – 1.75	ppm	7/10/25	N	Water additive used to control microbes.

Lead and Copper 2025								
Contaminant	Action Level (AL)	MCLG	90th Percentile Value	Range of Tap Sampling Results	Units	# of Sites Above AL of Total Sites	Violation Y/N	Sources of Contamination
Lead	15	0	3.40	0.00-110	ppb	1 out of 5	N	Corrosion of household plumbing systems; Erosion of natural deposits
Copper	1.3	1.3	0.22	0.004-0.23	ppm	0 out of 5	N	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives

Lead: Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Country Side MHP is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Country Side MHP at (814) 720-8808. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at: www.epa.gov/safewater/lead.

Country Side MHP prepared a service line inventory that includes the type of material contained in each service line in our distribution system. This inventory can be accessed by contacting us at (814) 720-8808.

Violations: In 2023, we failed to monitor for Arsenic and subsequently failed to issue a tier 3 public notification. In 2025, we failed to monitor for Perfluorooctanesulfonic Acid and Perfluorooctanoic Acid in the second quarter. A public notification further describing these violations is enclosed at the end of this report.

EDUCATIONAL INFORMATION:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, can be naturally occurring or result from urban storm water run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.
- In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Notice: Our source water is known to contain elevated sodium levels, individuals with high blood pressure or sodium restricted diets should be advised and it is recommended that such individuals consult with their physician.

Public Notice

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER FAILURE TO MONITOR

**ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE
ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.**

Monitoring Requirements Not Met for Country Side Mobile Home Park

Our water system violated several drinking water standards over the years. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In 2023, we failed to monitor for Arsenic and subsequently failed to issue a tier 3 public notification. In 2025, we failed to monitor for Perfluorooctanesulfonic Acid and Perfluorooctanoic Acid in the second quarter; therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminants we did not properly test for during the last year, the required sampling frequency of Arsenic, Perfluorooctanesulfonic Acid and Perfluorooctanoic Acid, how many samples we took, when samples should have been taken, and the date on which corrective action samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were taken
Arsenic	Annually	0	2023	N/A
Perfluorooctanesulfonic Acid	Quarterly	3	Second Quarter 2025	N/A
Perfluorooctanoic Acid	Quarterly	3	Second Quarter 2025	N/A

What happened? What was done?

In 2023, we failed to monitor for Arsenic and subsequently failed to issue a tier 3 public notification. In 2025, we failed to monitor for Perfluorooctanesulfonic Acid and Perfluorooctanoic Acid in the second quarter.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information regarding this notice, please contact Country Side Mobile Home Park at 814-720-8808.

Certified by:

Signature: _____

Date: 6/26/20

Print Name and Title: _____

TOBY KOPTA OWNER

As a representative of the Public Water system indicated above, I certify that public notification addressing the above violation was distributed to all customers in accordance with the delivery requirements outlined in Chapter 25 PA Code 109 Subchapter D of the Department of Environmental Protection (DEP's) regulations. The following methods of distribution were used: Enclosed in the 2025 CCR

PWS ID#: 6200028

Date distributed: 6/26/20